
### 2020 Compliance Update

March 18, 2021

**Board of Public Utilities Meeting** 

Presented by Heather Johnson Environmental Services Officer





### Santa Rosa Water - Roadmap to Compliance



### Applicable Rules, Regulations, Permit Requirements and 2020 Non-Compliance Events:

- Wastewater Treatment and Recycled Water
- Air Quality and Emissions
- Biosolids Land Application

Emerging Regulatory Issues and Opportunities

### NPDES Permit and Recycled Water Notice of Applicability

- NPDES Discharge Permit
- Recycled Water Notice of Applicability





#### **2020 Non-Compliance Summary**

# Wastewater Treatment and Recycled Water

Non-compliant Events	Description	Cause
Monitoring	Missed monitoring for Total Coliform, Chloride, Total Suspended Solids, Biochemical Oxygen Demand, on-line turbidity	Various reasons including equipment malfunction, staff errors, and COVID-19 reduced staffing levels.
Reclamation System	Incidental runoff	Leaking valves, over- irrigation, and pipeline breaks.
Ultra-Violet Disinfection	3 minutes and 38 sec and 21,000 gallons	Electronic connection in the communication board not properly seated.



### Title V Air Quality Permit and Permit to Operate

- Title V Air Permit for Major Sources
- Permit to Operate





#### **2020 Non-Compliance Summary**

## Air Quality and Emissions

Non-compliant Events	Description	Cause
Engine Firing Rate	Annual Monitoring on Combined Heat and Power Engine 4 exceeded the engine firing rate limitation in June and November	Suspected engine firing rate exceedance due to reduced biogas production from digesters in 2020.







### Biosolids

- Land Application Notice of Applicability
- (no non-compliance events in 2020)





- Laguna de Santa Rosa Nutrient TMDL
- Regional Salt and Nutrient Monitoring
- Engineering Evaluation of Discharge Outfalls
- Recycled Water Pond Pathogen Monitoring
- PFAS Monitoring

### **Emerging Regulatory Issues and Opportunities**

Questions?

Thank you.

