

**DEPARTMENT OF PLANNING & ECONOMIC DEVELOPMENT
ENGINEERING DEVELOPMENT SERVICES**

**EXHIBIT "A"
11/07/2023**

**Food for Thought Food Bank
2351 Circadian Way
CUP23-056**

Tenant Improvement Conditions

- I. Developer's engineer shall obtain the current City Design and Construction Standards and the Engineering Development Services Department's Standard Conditions of Approval dated August 27, 2008 and comply with all requirements therein unless specifically waived or altered by written variance by the City Engineer.
- II. **Per City Code Section 18-12.015 (C), all properties including commercial and industrial parcels shall be subject to public improvement requirements when the value of any proposed building or site improvement exceeds \$200,000.00. A formal review of the valuation will commence during review of the building permit application. If the valuation is determined to be above the \$200,000 threshold, the project may be required to install or modify public improvements such as sidewalks, curb and gutter, pedestrian ramps, driveway approaches, planter strips and bike lanes. Additional right-of-way and easement dedications may also be required to support the current or future expansion of the roadway in order to meet adopted City Standards, General Plan requirements or area specific plans. Contact the Engineering Division of the Planning and Economic Development Department at 707-543-3200 to discuss specific requirements.**
- III. In addition, the following summary constitutes the recommended conditions of approval on the subject application/development based on the plans stamped received **September 8, 2023**:

PUBLIC STREET IMPROVEMENTS

1. Any non-standard sidewalk sections and driveway approaches along the property's frontage shall be upgraded to the current standard in order to ensure a compliant path of travel within the public right-of-way or public easements and to mitigate any potential trip hazards. Per City Code Section 13-32.020, the abutting property owner shall maintain the sidewalk in a manner that avoids creating a dangerous situation for the property owner and any members of the public utilizing the corridor.

2. An encroachment permit shall be obtained from the Planning and Economic Development Department prior to performing any work within or adjacent to the public right-of-way.

STORM WATER COMPLIANCE

3. Note on the plans submitted with the building permit application that “no debris, soil, silt, bark, slash, sawdust, rubbish, cement or concrete washings, oil or petroleum products, or other organic or earthen material from any construction or associated activity of whatever nature, shall be allowed to enter into or be placed where it may be washed by rainfall into the storm drain system. When operations are complete, any excess material or debris shall be removed from the work area.”
4. As applicable, the developer’s engineer shall comply with all requirements of the latest edition of the City Storm Water Low Impact Development Technical Design Manual.

STORM DRAINAGE

5. Any needed drainage facilities and drainage easements shall be provided to the satisfaction of the City Engineer and shall be designed per the Sonoma County Water Agency’s Flood Control Design Manual and the City of Santa Rosa Design and Construction Standards at the developer’s expense.

BUILDING

6. Obtain building permits for the proposed project.

WATER AND WASTEWATER

7. Demand fees may be required and shall be determined during review of the building permit application. Submit the type of use in each portion of the building (office, warehouse, lab, manufacturing, cultivation, etc.) and the square footage of each usage type with the building permit application. If the proposed use involves a cannabis growing operation, provide the number of plants and the estimated peak monthly water and sewer usage. The applicant may contact the Water Engineering Services division at (707)-543-4300 to obtain a preliminary fee calculation.
8. All irrigation and domestic water services shall be protected with a reduced pressure backflow device per City Standard 876. Backflow additions or upgrades shall be required as part of the building permit review. The location of all existing or proposed backflow devices shall be shown on the utility plan submitted with the building permit application.
9. The existing water service shall be sized to support any additional fire and domestic demand. If the building is not served by an automatic fire sprinkler system, it is possible that the proposed tenant improvement will require the

installation of fire sprinklers within the building and a dedicated fire service per City Standard 880. All modifications to the existing water system shall be performed under an encroachment permit. The water service size shall be determined based on flow calculations submitted by the sprinkler designer.

10. Properties currently protected by automatic fire protection systems may have backflow devices on the dedicated fire service that do not meet current standards. All dedicated fire services shall be protected with a double detector check device per City Standard 880. Existing fire services protected by a single check device may require an upgrade per City Standard 880 as part of the tenant improvements. Contact Water Engineering Services at 707-543-4200 or email watereng@srcity.org to determine the existing backflow type and to understand the specific requirements that will be placed on the building permit application. Any upgrades to the backflow device shall be installed under an encroachment permit.
11. If the project involves the addition of a new fire service or modifications to an existing service, an approved Fire permit for the onsite dedicated fire line shall be obtained prior to issuance of the encroachment permit for the backflow device. The onsite permit application and plan should be submitted to the Fire Department prior to applying for the encroachment permit.
12. A sewer cleanout per City Standard 513/513A must be installed on the existing sewer lateral if one does not already exist. The location of the cleanout must be shown on the utility plan submitted with the building permit application. The type of cleanout and the placement shall be based on the depth of the existing lateral. The installation of the clean out must be performed under an encroachment permit.
13. If additions or modifications to the existing landscaping are proposed under the building permit application, a dedicated irrigation meter shall be installed to serve the existing or proposed landscaping if one does not already exist. The Director of Santa Rosa Water may approve a variance deferring the installation of the irrigation meter if special circumstances exist on the property that would result in the installation creating practical difficulties or unnecessary hardships.
14. If additional fire lines and water meters are required, Santa Rosa Water may require all individual existing and new water services to be consolidated and installed as a combination service per City Standard 870. Consolidation shall require the abandonment of any unused water services at the main. This determination will be made during review of the building permit application.
15. Any additions or modifications to the existing landscaping shall be consistent with the Water Efficient Landscape Ordinance adopted by the Santa Rosa City Council, Ordinance 4051, on December 1, 2015. Landscape plans will be reviewed during the building permit stage to determine compliance with the ordinance.

ENVIRONMENTAL COMPLIANCE

16. Tenant improvements performed in conjunction with a change of use or an expansion of an existing use may result in additional requirements associated with the discharge to the City's public wastewater system. Contact the Water Department's Environmental Compliance section at 707-543-3369 to determine the necessary permitting path and to better understand the specific requirements that will be brought forward during the review of the building permit application.

FIRE – (from Mike Johnson dated October 12, 2023)

17. Fire service features for buildings, structures and premises shall comply with all City adopted building standards, California Code of Regulations Title 24 Building Standards and Santa Rosa City Code.
18. Any alterations to the buildings fire sprinkler or alarm system will require a Fire Department Permit.

RECREATION AND PARKS

19. If dead or dying street trees are present in the frontage, new street trees shall be planted by the developer.
20. Street trees shall be installed and planted by the developer along the project frontage(s). Selection shall be made from the City's approved master plan list and approved by the City Parks Department. Planting shall be completed in accordance with City "Standards and Specifications for Planting Parkway Trees." Contact the Recreation & Parks Department Office at (707) 541-3770 for copies of the master street tree list. This declaration shall be added to the General Notes of the improvement plans.
21. Property owners shall be responsible for the irrigation and maintenance of the street trees and the maintenance of the planter strips in front of and alongside of their project for perpetuity.



11/07/2023

CLEVE GURNEY, PE - EDS SUPERVISING ENGINEER