

From: Juanita Sanchez <sancheju7@gmail.com>
Sent: Thursday, September 21, 2023 11:26 AM
To: Bisla, Sachnoor
Subject: Re: [EXTERNAL] Topsy Taco Minor Conditional Permit
Attachments: image001.jpg; Blueprint Topsy Taco.pdf; Topsy Taco Santa Rosa Fire Permit .pdf

Hello Sachnoor,

Thank you for reaching out. We called multiple agencies to get a sound analysis study done and had no luck. I have attached our response to the last list of requirements. Please let me know if you have any questions .

Planning Division

1. Sound Management Plan:

Attached is a blueprint of current restaurant design with proposed modification to reduce sound. Previously entry into the bar came from the patio area. We are moving the entry to Entry in blue. This creates more distance between residences and we are better able to control the line and noise level instead of having individuals congregate in patio areas increasing noise level.

Secondly we will be moving the band and the DJ to the back area. This will create distance between the entry and the live music to reduce how much noise is heard when doors are opened for entry.

Thirdly we will be placing sound barriers on all windows. Current windows are single pane therefore allowing more noise to travel outside. By installing sound barriers on all windows marked in red, there will be a noise reduction.

Last call for all alcohol will be no later than 1:30am to allow all occupants to finish their last drink and leave the establishment. Secondly security will be placed outside to break down any groups congregating and creating noise.

Lastly a decibel reader will be kept on premises and used through the night to keep music level at allowed level.

2. Fire Department

The Fire Department permit has been maintained and is current. A copy of the permit has been attached.

On Wed, Sep 20, 2023 at 3:42 PM Bisla, Sachnoor <sbisla@srcity.org> wrote:

Hello,

I am checking in to see where we are at in the process of completing the below application requirements. Feel free to email me if you have any questions or if I can be of any help!

Thanks,

Noor

Sachnoor Bisla | City Planner

Planning and Economic Development Department | 100 Santa Rosa Ave | Santa Rosa, CA 95404

Tel. (707) 543-3223 | Fax (707) 292-0963 | sbisla@srcity.org