



Laguna Treatment Plant Disinfection System Improvements

Emma Walton, Deputy Director of
Engineering Resources
Board of Public Utilities | Study Session
July 18, 2019




Project Background


- Pre-1998 Disinfected with Gaseous Chlorine
 - 1998 Commission UV System
67 MGD Capacity
 - 2012 DDW De-Rated UV System
~~67~~ > 48.5 MGD Capacity
 - 2013-2015 Alternatives Analysis
- Issue #1: Insufficient Capacity
Issue #2: End of Useful Life

2016 Preferred Alternative

- Replace (E) UV with (N) UV
- Add Supplemental Hypo-Chlorination
- Add On-Site Diversion



Project Timeline



The diagram features a horizontal timeline bar divided into seven segments representing the years 2016 through 2022. Above the bar, three key events are marked with vertical lines and diamond symbols: 'Jan 2016 BPU Approved \$2.8M PWO with Carollo', 'Nov 2016 BPU Approved \$4.7M MOU with Calgon', and 'July 2016 Supplemental Hypo Removed from Scope'. The title 'Project Timeline' is positioned at the top right, with a horizontal arrow pointing to the right.

Jan 2016
BPU Approved
\$2.8M PWO
with Carollo

Nov 2016
BPU Approved
\$4.7M MOU
with Calgon

2016

2017

2018

2019

2020

2021

2022

July 2016
Supplemental
Hypo Removed
from Scope

MOU with Calgon

Intent: Pre-Selection of Equipment

- Equipment Configurations Differ Significantly
- Designing Around Unknown Equipment = Inefficiencies and CCOs



Calgon Carbon



Xylem/Wedeco



Trojan




Suez/Ozonix

MOU with Calgon

Benefits of Pre-Selection

- Eliminates Design Inefficiencies
- City Selection based on Best Value
- Competitive Pricing
- Minimizes Risk



MOU with Calgon

- BPU Approved MOU Nov 2016
- Guaranteed Price of Equipment \$4,726,500
- Price Held for 18 months
- MOU Expired June 2018
- Communication with Calgon has been On-going
- *Need to Renegotiate and Re-Approve MOU



Project Timeline



2017 Value Engineering Effort

Intent – Consider More Economical Disinfection Options

- Reconsider Supplemental Hypo-Chlorination
- Review Design Parameters



Reconsider Supplemental Hypo-Chlorination

Original Approach - Install Supp-Hypo in Advance of New UV

- Benefits
 - Utilize (E) Chlorine Contact Basins
 - Extend Useful Life of (E) UV
 - Push out Capital Investment
- Problem
 - UV Beyond Useful Life
 - Need Capital Investment Now
 - Regional Board has Requested a Compliance Schedule

Question Becomes: Are there benefits to having two Disinfection Systems?



Reconsider Supplemental Hypo-Chlorination

New UV System (67 mgd)

**New UV (43 mgd) w/
Supp-Hypo (30 mgd)**

Single Process

Dual/Parallel Processes

67 mgd Capacity

73 mgd Capacity

↑ Capital

↓ Capital

↓ O&M

↑ O&M

Cost Considerations

	New UV System	New UV w/ Supp-Hypo
Capital Costs (\$M)		
New UV	\$20.5	\$14.5
New Supp-Hypo	-	\$2.5
Off-Spec Diversion	\$15.5	\$15.5
Total Capital Costs	\$36.0	\$32.5
O&M Costs (\$M)		
Annual O&M Costs	\$0.53	\$0.6
20-year O&M Costs	\$10.6	\$12.0
Total Capital + 20-yr O&M	\$46.6	\$44.5

Operational/Regulatory Considerations

- In-plant Upstream Processes
 - Limits Nutrient Removal Options
- Disinfection System Operations
 - Difficult Startup/Shutdown
 - Difficult Flow Split
 - Multiple Disinfection Compliance Points
- Reuse Operations
 - Potential Benefits for Geysers Biofouling
 - Disinfection By-Products may Limit Discharge Abilities

Recommended Disinfection Approach


Remove Supp-Hypo, Construct Full Capacity UV

- Single Process
- Provides most Future Flexibility
- Challenges with Supplemental Hypo-Chlorination don't overcome Benefits of Additional Capacity




Review Design Parameters

- Ultraviolet Transmittance (UVT)
 - Original Design - 55%
- Capacity
 - Original Design - 67 mgd




Design Parameter Review - UVT

VE Recommendation
~~55%~~ → 61%



Design Parameter Review - Capacity

VE Recommendation
~~67 mgd~~ → 58 mgd



Recommended Design Parameters


~~55%~~ → **61% UVT** (VE Recommendation)

~~67 mgd~~ → 58 mgd (VE Recommendation)
+ 6 mgd (10% Operational Buffer)
= **64 mgd (Design Process Capacity)**

+ 6 mgd (10% Safety Factor)
= 70 mgd (Peak Hydraulic Capacity)



Project Timeline



First Next Step

- Amend Carollo Contract (~\$1.5M anticipated)
 - July 29, 2019 Contract Review Subcommittee
 - Fall 2019 Anticipated BPU Approval
- Why Amend?
 - Value Engineering Effort
 - Delay in Project
 - Changes in Scope

Future Next Steps

- Re-Execute MOU with Calgon
 - Late 2019 BPU Approval
- Bond Issuance
 - Late 2020 BPU Approval
- Award Construction Contract
 - Early 2021 BPU Approval
 - Late 2022 Commission
Diversion/UV System



Questions?

