

DEPARTMENT OF PLANNING & ECONOMIC DEVELOPMENT
ENGINEERING DEVELOPMENT SERVICES

EXHIBIT "A"
May 20, 2020

SGI DBA Authentic 707 Cannabis Retail and Delivery
CUP19-102
3175 Range Avenue

Standard Tenant Improvement Conditions – Downtown

Proposed right-of-way and site improvements are limited to path of travel and outdoor seating

- I. Developer's engineer shall obtain the current City Design and Construction Standards and the Engineering Development Services Department's Standard Conditions of Approval dated August 27, 2008 and comply with all requirements therein unless specifically waived or altered by written variance by the City Engineer.
- II. In addition, the following summary constitutes the recommended conditions of approval on the subject application/development based on the approved plans, which will include the shared parking and solid waste enclosure at 819 Piner Road.

PUBLIC STREET IMPROVEMENTS

1. It is recommended that any non-standard sidewalk sections and driveway approaches along the property's frontage be upgraded to the current standard in order to ensure a compliant path of travel within the public right-of-way or public easements and to mitigate any potential trip hazards. Per City Code Section 13-32.020, the abutting property owner shall maintain the sidewalk in a manner that avoids creating a dangerous situation for the property owner and any members of the public utilizing the corridor.
2. An encroachment permit shall be obtained from the Planning and Economic Development Department prior to performing any work within or adjacent to the public right-of-way.

STORM WATER COMPLIANCE

3. Note on the plans submitted with the building permit application that "no debris, soil, silt, bark, slash, sawdust, rubbish, cement or concrete washings, oil or petroleum products, or other organic or earthen material from any construction or associated activity of whatever nature, shall be allowed to enter into or be placed

where it may be washed by rainfall into the storm drain system. When operations are complete, any excess material or debris shall be removed from the work area.”

4. As applicable, the developer’s engineer shall comply with all requirements of the latest edition of the City Storm Water Low Impact Development Technical Design Manual.

STORM DRAINAGE

5. Any needed drainage facilities and drainage easements shall be provided to the satisfaction of the City Engineer and shall be designed per the Sonoma County Water Agency’s Flood Control Design Manual and the City of Santa Rosa Design and Construction Standards at the developer’s expense.

BUILDING

6. Obtain building permits for the proposed project.
7. Any proposed outdoor seating will be reviewed during the building permit stage to ensure that ADA compliant seating and path of travel requirements are met. The placement of any outdoor seating must be performed under an encroachment permit.

WATER AND WASTEWATER

8. Demand fees may be required and shall be determined during review of the building permit application. Submit the type of use in each portion of the building (office, warehouse, lab, manufacturing, cultivation, etc.) and the square footage of each usage type with the building permit application. If the proposed use involves a cannabis growing operation, provide the number of plants and the estimated peak monthly water and sewer usage. The applicant may contact the Water Engineering Services division at (707)-543-4300 to obtain a preliminary fee calculation.
9. All irrigation and domestic water services shall be protected with a reduced pressure backflow device per City Standard 876. Backflow additions or upgrades shall be required as part of the building permit review. The location of all existing or proposed backflow devices shall be shown on the utility plan submitted with the building permit application.
10. The existing water service shall be sized to support any additional fire and domestic demand. If the building is not served by an automatic fire sprinkler system, it is possible that the proposed tenant improvement will require the installation of fire sprinklers within the building and a dedicated fire service per City Standard 880. All modifications to the existing water system shall be performed under an encroachment permit. The water service size shall be determined based on flow calculations submitted by the sprinkler designer.

11. An approved Fire permit for the onsite dedicate fire line shall be obtained prior to issuance of the encroachment permit. The onsite permit application and plan should be submitted to the Fire Department prior to applying for the encroachment permit.
12. Properties currently protected by automatic fire protection systems may have backflow devices on the dedicated fire service that do not meet current standards. All dedicated fire services shall be protected with a double detector check device per City Standard 880. Existing fire services protected by a single check device may be required to upgrade the device per City Standard 880 as part of the tenant improvements. Contact Water Engineering Services at 707-543-4200 or email watereng@srcity.org to determine the existing backflow type and to understand the specific requirements that will be placed on the building permit application. Any upgrades to the backflow device shall be installed under an encroachment permit.
13. A sewer cleanout per City Standard 513/513A must be installed on the existing sewer lateral if one does not already exist. The location of the cleanout must be shown on the utility plan submitted with the building permit application. The type of cleanout and the placement shall be based on the depth of the existing lateral. The installation of the clean out must be performed under an encroachment permit.
14. If additional fire lines and water meters are required, Santa Rosa Water may require all individual existing and new waters service to be consolidated and installed as a combination service per City Standard 870. Consolidation shall require the abandonment of any unused water services at the main. This determination will be made during review of the building permit application.
15. Any additions or modifications to the existing landscaping shall be consistent with the Water Efficient Landscape Ordinance adopted by the Santa Rosa City Council, Ordinance 4051, on December 1, 2015. Landscape plans will be reviewed during the building permit stage to determine compliance with the ordinance.

ENVIRONMENTAL COMPLIANCE

16. Tenant improvements performed in conjunction with a change of use or an expansion of an existing use may result in additional requirements associated with the discharge to the City's public wastewater system. Contact the Water Department's Environmental Compliance section at 707-543-3369 to determine the necessary permitting path and to better understand the specific requirements that will be brought forward during the review of the building permit application.

FIRE

17. Construction permits associated with the tenant improvements shall comply with all adopted building standards as described in Title 24 and City Code.

18. If the building is not served by an automatic fire protection system, the installation of fire sprinklers will be required as part of the tenant improvement. Sprinklers will be required throughout the building. The project may be exempt from the installation of sprinklers if there is no proposed change in use or occupancy and the following criteria are met:
 - a. The proposal is altering 50% or less of the existing gross floor area of the building.
 - b. The proposal involves the addition of 25% or less of the existing gross floor area of the building.
 - c. The proposal includes both alterations and additions to the building footprint that total 50% or less of the existing gross floor area of the building.

To verify that the project is consistent with the above, contact the Fire Department at 707-543-3500.

19. When fire sprinklers are required as part of the tenement improvement, a hydrant must be located within 100' of the required Fire Department Connection (FDC). If a hydrant does not exist within this distance a new hydrant may be required.
20. All proposed vehicle gates and traffic calming devices shall be reviewed and approved under a separate construction permit submitted directly to the Fire Department. All required permits must be obtained prior to the construction of any gates or traffic calming devices.