



PJC & Associates, Inc.

Consulting Engineers & Geologists

March 10, 2020

Job No. S2028.01

Sharon Evans
1998 Long Leaf Court
Santa Rosa, CA 95403

**Subject: Geotechnical Review
Proposed Fiberglass Swimming Pool
1998 Long Leaf Court
Santa Rosa, California**

References: Report titled, "Geotechnical Exploration Report on Proposed Custom Residence at 1998 Long Leaf Court, Santa Rosa, California," prepared by KC Engineering Company, dated November 5, 2018.

Site Pool Plans, Sheets S-1 through S-3, prepared by West Coast Fiberglass Pools, dated December 12, 2019.

Pool Engineering, Pages 1 through 8, prepared by Donald Poindexter, dated January 16, 2020.


PJC & Associates, Inc. (PJC) is pleased to submit this letter presenting the results of our geotechnical review of the above captioned project.

Based on the results of our review of the geotechnical report and project plans, it appears the project is feasible from a geotechnical perspective. However, due to the highly expansive soils encountered at the site, the fiberglass pool should be installed in accordance with the specifications for expansive soils contained in the project plans. Observation and testing services should be provided by PJC to verify that the recommendations and specifications are carried out during construction; these services should include observing the pool excavation, field density testing of engineered fill and installation of subsurface drainage facilities.

We trust that this is the information that you require at this time. If you have any questions concerning the content of this letter please call.

Sincerely,

PJC & Associates, Inc.



Anthony J. DeMartini
Geotechnical Engineer
GE 2750, California

