

Evaluation of City Water System's Response in Fountaingrove during the October 2017 Fire



OUR FUTURE IN EVERY DRÖP

September 6, 2018
Board of Public Utilities

Evaluation of Fountaingrove Water System

- Objective 3rd party evaluation
- Improve emergency response & system resilience
- Confirm water system met all City Codes & industry standards
- Understand how system performed during the fire

Water System Performance & Operational Response Report


- Valuable tool for improving emergency response & system resiliency
- Incorporate lessons learned to improve water system operations



OUR FUTURE IN EVERY DRÖP

Recommendations

- Investigate ways to increase pumping reliability in higher-pressure zones
- Study technical solutions to prevent openly flowing appurtenances
- Consider improvements to increase SCADA system reliability



OUR FUTURE IN EVERY DRÖP

Recommendations

- Incorporate lessons learned in future Master Plan updates
- Include resiliency planning
- Examine additional interconnections & pressure regulating valves
- Study feasibility of providing off-line storage



CITY OF SANTA ROSA

Water Master Plan Update



OUR FUTURE IN EVERY DRÖP

Questions?



OUR FUTURE IN EVERY DRÖP