

August 30, 2019

Re: Solful
755 Famers Lane, Suite 140
Santa Rosa, CA 95405
Cannabis Retail
City of Santa Rosa – Conditional Use Permit Application

As required by the City of Santa Rosa's Cannabis – Conditional Use Permit Application, the Owner has hired TEP Engineering to address three items regarding HVAC filtration and noise. These three items are "Storage of Cannabis Products/Inventory", "Odor Control – Engineering Controls" and "Noise".

Cannabis Retail - Storage of Cannabis Products/Inventory

The project as proposed shall comply with the City of Santa Rosa's storage of cannabis products/inventory standards set forth in Zoning Code Chapter 20-46. Solful will store packaged edible cannabis goods in spaces that have temperature and humidity controlled heating, ventilation and air conditioning (HVAC) systems. The outside and recirculated air for these HVAC systems will include filters that mitigate environmental contaminants such as smoke and dust. These filtration systems must be specified and sized properly by a Professional Mechanical Engineer and maintained by the Owner per the manufacturer's instructions. The area in which edible medical cannabis goods are stored also may not be exposed to direct sunlight.


Cannabis Retail - Odor Control – "Engineering Controls"

The project as proposed shall comply with the City of Santa Rosa's odor mitigation standards set forth in Zoning Code Chapter 20-46. The industry accepted method to remove cannabis odors for airstreams is carbon filtration. Solful will install activated carbon filter canisters or inline filters on their exhaust systems serving spaces at risk for emitting cannabis odors. Solful will also install activated carbon inline filters on their recirculating air systems serving spaces at risk for emitting cannabis odors. These carbon filters are designed for the control of VOC's, odors and other gaseous contaminants. The spaces at risk for emitting cannabis odors are noted on the odor-control floor plan provided by Solful; these spaces include the Dispensary, Cannabis Goods Storage/Store, Cannabis Goods Storage spaces. The exhaust and recirculated air for these spaces will pass through an activated carbon filter, which uses chemical adsorption to remove organic compounds from the airstream. These organic compounds carrying the cannabis odor are captured through a process of adsorption in the microporous carbon. The activated carbon filtration systems must be sized properly by a Professional Mechanical Engineer and maintained by the Owner per the manufacturer's instructions. Suitable activated carbon filters manufacturers include: Camfil, Purafil or approved equivalent by a Professional Engineer.

HVAC Equipment Noise


HVAC equipment shall comply with the City of Santa Rosa's Chapter 17- 16 (Noise) requirements. These HVAC systems must be specified and sized properly by a Professional Mechanical Engineer and maintained by the Owner per the manufacturer's instructions.

Sincerely,



TEP Engineering
Andrew Souza, P.E., CPD, GPD, LEED AP BD+C





LEGEND
SPACES AT RISK FOR EMITTING CANNABIS ODORS

COPYRIGHT MATERIALS RELEASE- To the extent that your application submittal packet includes plans or drawings prepared by a licensed, registered or certified professional, as defined pursuant to the California Health and Safety Code Section 19851 or Business and Professions Code Section 5536.25, such as a licensed engineer, architect or other design professional, the City must first obtain the signature release and permission of said professional prior to publication or reproduction of any such plans or drawings. Such drawings and plans may also be protected by copyright laws. The City of Santa Rosa hereby requests permission to reproduce and publish plans and drawings submitted with your application packet for purposes of more effectively and efficiently facilitating the entitlement review process, including making plans and drawings available on the City's website for public review and providing electronic reproductions to the City's review boards. The purpose of this request is limited solely to the purpose of facilitating the timely review of this application, and the plans and drawings will not be utilized by the City for other purposes. To assist the City in this process, please provide below the signatures of all of those who have prepared plans and drawings to be submitted with this application. (PROJECT: 755 FARMERS LANE, SUITE 140)

Engineer Name: ANDREW SOUZA, P.E. (MECHANICAL ENGINEER)
Phone: 707-538-0400
Email Address: andy@tep.net

ENGINEER /SURVEYOR'S SIGNATURE Andy Souza

Architect Name: _____
Phone: _____
Email Address: _____

ARCHITECT/DESIGNER'S SIGNATURE _____

Landscape Architect Name: _____
Phone: _____
Email Address: _____

LANDSCAPE ARCHITECT/DESIGNER
SIGNATURE _____