

**DEPARTMENT OF PLANNING & ECONOMIC DEVELOPMENT
ENGINEERING DEVELOPMENT SERVICES**

**EXHIBIT "A"
MAY 28, 2021**

**ERUDITE VENTURE CANNABIS –
RETAIL SALES FOR MEDICAL AND ADULT USE
AND DELIVERY SERVICE
3059 COFFEY LANE
CUP19-056**

- I. Developer's engineer shall obtain the current City Design and Construction Standards and the Engineering Development Services Department's Standard Conditions of Approval dated August 27, 2008 and comply with all requirements therein unless specifically waived or altered by written variance by the City Engineer.
- II. Per City Code Section 18-12.015 (C), all properties including commercial and industrial parcels shall be subject to public improvement requirements when the value of any proposed building or site improvement exceeds \$200,000.00. A formal review of the valuation will commence during review of the building permit application. If the valuation is determined to be above the \$200,000 threshold, the project may be required to install or modify public improvements such as sidewalks, curb and gutter, pedestrian ramps, driveway approaches, planter strips and bike lanes. Additional right-of-way and easement dedications may also be required to support the current or future expansion of the roadway in order to meet adopted City Standards, General Plan requirements or area specific plans. Contact the Engineering Division of the Planning and Economic Development Department at 707-543-3200 to discuss specific requirements.
- III. In addition, the following summary constitutes the recommended conditions of approval on the subject application/development based on the plans stamped received May 3, 2021:

PUBLIC STREET IMPROVEMENTS

1. It is recommended that any non-standard sidewalk sections and driveway approaches along the property's frontage be upgraded to the current standard in order to ensure a compliant path of travel within the public right-of-way or public easements and to mitigate any potential trip hazards. Per City Code Section 13-32.020, the abutting property owner shall maintain the sidewalk in a manner that avoids creating a dangerous situation for the property owner and any members of the public utilizing the corridor.

2. An encroachment permit shall be obtained from the Planning and Economic Development Department prior to performing any work within or adjacent to the public right-of-way.
3. A dedication of a Public Utility Easement (PUE) located behind the existing Property line of a 7 feet minimum width shall be dedicated to the City of Santa Rosa along the project frontage if one does not currently exist. The applicant shall submit a preliminary title report at first submittal. The public utility easement dedication documents shall be prepared by a licensed Land Surveyor and or Civil Engineer and reviewed and approved by the City Engineer prior to building permit issuance. A copy of the PUE document shall be recorded at the County of Sonoma County Recorder's office. The applicant shall submit a dimensioned street-frontage, cross-section on the plans depicting the Half-street improvements, the right of way line and the Public utility easement, and lane widths.
4. If the project valuation is over the \$200,000 valuation threshold then the frontage improvements shall be installed by the applicant. Coffey Lane frontage exists as an improved "modified" Main Street along the entire frontage per City Standard detail # 200G. The existing Half width street improvements consist of 1-Travel Lane, a parking lane, a 5-feet wide bike lane, curb and gutter, a 5-feet wide filled in planter strip, a 5 feet wide sidewalk. New Improvements shall consist of installation of a ADA compliant driveway apron, and the re-painting of bike lane symbols and lane striping by the applicant along the frontage. The final project valuation shall be submitted at the first building plan check submittal.
5. As shown on the applicant's submittal, the street frontage landscape planter that was previously filled-in shall be replanted and re-installed with landscaping and or City street trees per City Standards.
6. The frontage curb line shall be re-painted red and "No Parking at anytime" signs installed along the property frontage due to the existing City Bus stop located at the frontage that conflicts with the frontage parking lane use on Coffey Lane.

STORM WATER COMPLIANCE

7. Note on the plans submitted with the building permit application that "no debris, soil, silt, bark, slash, sawdust, rubbish, cement or concrete washings, oil or petroleum products, or other organic or earthen material from any construction or associated activity of whatever nature, shall be allowed to enter into or be placed where it may be washed by rainfall into the storm drain system. When

operations are complete, any excess material or debris shall be removed from the work area."

8. As applicable, the developer's engineer shall comply with all requirements of the latest edition of the City Storm Water Low Impact Development Technical Design Manual.

STORM DRAINAGE

9. Any needed drainage facilities and drainage easements shall be provided to the satisfaction of the City Engineer and shall be designed per the Sonoma County Water Agency's Flood Control Design Manual and the City of Santa Rosa Design and Construction Standards at the developer's expense. All storm water drainage shall be directed to the Public Street unless easements are in place to cross property lines.

BUILDING

10. Obtain building permits for the proposed project.

WATER AND WASTEWATER

11. Demand fees may be required and shall be determined during review of the building permit application. Submit the type of use in each portion of the building (office, warehouse, lab, manufacturing, cultivation, etc.) and the square footage of each usage type with the building permit application. If the proposed use involves a cannabis growing operation, provide the number of plants and the estimated peak monthly water and sewer usage. The applicant may contact the Water Engineering Services division at (707)-543-4300 to obtain a preliminary fee calculation.
12. All irrigation and domestic water services shall be protected with a reduced pressure backflow device per City Standard 876. Backflow additions or upgrades shall be required as part of the building permit review. The location of all existing or proposed backflow devices shall be shown on the utility plan submitted with the building permit application.
13. The existing water service shall be sized to support any additional fire and domestic demand. If the building is not served by an automatic fire sprinkler system, it is possible that the proposed tenant improvement will require the installation of fire sprinklers within the building and a dedicated fire service per City Standard 880. All modifications to the existing water system shall be performed under an encroachment permit. The water service size shall be determined based on flow calculations submitted by the sprinkler designer.
14. Properties currently protected by automatic fire protection systems may have backflow devices on the dedicated fire service that do not meet current standards. All dedicated fire services shall be protected with a double detector check device per City Standard 880. Existing fire services protected by a single

check device may require an upgrade per City Standard 880 as part of the tenant improvements. Contact Water Engineering Services at 707-543-4200 or email watereng@srcity.org to determine the existing backflow type and to understand the specific requirements that will be placed on the building permit application. Any upgrades to the backflow device shall be installed under an encroachment permit.

15. If the project involves the addition of a new fire service or modifications to an existing service, an approved Fire permit for the onsite dedicated fire line shall be obtained prior to issuance of the encroachment permit for the backflow device. The onsite permit application and plan should be submitted to the Fire Department prior to applying for the encroachment permit.
16. A sewer cleanout per City Standard 513/513A must be installed on the existing sewer lateral if one does not already exist. The location of the cleanout must be shown on the utility plan submitted with the building permit application. The type of cleanout and the placement shall be based on the depth of the existing lateral. The installation of the clean out must be performed under an encroachment permit.
17. If additions or modifications to the existing landscaping are proposed under the building permit application, a dedicated irrigation meter shall be installed to serve the existing or proposed landscaping if one does not already exist. The Director of Santa Rosa Water may approve a variance deferring the installation of the irrigation meter if special circumstances exist on the property that would result in the installation creating practical difficulties or unnecessary hardships.
18. If additional fire lines and water meters are required, Santa Rosa Water may require all individual existing and new water services to be consolidated and installed as a combination service per City Standard 870. Consolidation shall require the abandonment of any unused water services at the main. This determination will be made during review of the building permit application.
19. Any additions or modifications to the existing landscaping shall be consistent with the Water Efficient Landscape Ordinance adopted by the Santa Rosa City Council, Ordinance 4051, on December 1, 2015. Landscape plans will be reviewed during the building permit stage to determine compliance with the ordinance.

ENVIRONMENTAL COMPLIANCE

20. Tenant improvements performed in conjunction with a change of use or an expansion of an existing use may result in additional requirements associated with the discharge to the City's public wastewater system. Contact the Water Department's Environmental Compliance section at 707-543-3369 to determine the necessary permitting path and to better understand the specific requirements that will be brought forward during the review of the building permit application.

FIRE

21. Construction permits associated with the tenant improvements shall comply with all adopted building standards as described in Title 24 and City Code.
22. If the building is not served by an automatic fire protection system, the installation of fire sprinklers will be required as part of the tenant improvement. Sprinklers will be required throughout the building. The project may be exempt from the installation of sprinklers if there is no proposed change in use or occupancy and the following criteria are met:
 - a. The proposal is altering 50% or less of the existing gross floor area of the building.
 - b. The proposal involves the addition of 25% or less of the existing gross floor area of the building.
 - c. The proposal includes both alterations and additions to the building footprint that total 50% or less of the existing gross floor area of the building.

To verify that the project is consistent with the above, contact the Fire Department at 707-543-3500.

23. When fire sprinklers are required as part of the tenement improvement, a hydrant must be located within 100' of the required Fire Department Connection (FDC). If a hydrant does not exist within this distance a new hydrant may be required.
24. All proposed vehicle gates and traffic calming devices shall be reviewed and approved under a separate construction permit submitted directly to the Fire Department. All required permits must be obtained prior to the construction of any gates or traffic calming devices.
25. Twelve inch illuminated building address characters shall be provided per Fire Department standards. An illuminated address directory monument sign shall be provided at each entrance to the property.
26. Storage or use of any hazardous materials at the site will require a Hazardous Materials Inventory Statement to be submitted to the Fire Dept. for review via the California Environmental Reporting System (CERS). Materials in excess of the permit amounts will require a Hazardous Materials Management Plan to be submitted to the Fire Dept. for review and approval and may require payment of annual Hazardous Material Use or Hazardous Waste Generator permit fees.

27. The building will be required to be protected by automatic fire sprinkler system.
 - a. The project proposes to alter more than 50% of the existing floor area.
28. Provide a Fire Department key box (Knox box) access to the building and if a gate is installed across the driveway Opticom and key-switch/Knox pad-lock access through electric/manual gates will be required.



Carol Dugas
EDS Project Engineer

E:\ENG\CEC\CUP\COFFEY LANE 3059 ERUDITE Venture cannabis