


City-Wide Energy Efficiency, Renewables, and Microgrid Feasibility Study




October 13, 2021



1 Energy Efficiency

– Scope Overview

- Perform Site Investigations for 47 Facilities
- Provide the City:
 - Energy Efficiency Measures
 - Reducing Energy Consumption
 - Addressing Deferred Maintenance
 - Supporting City Electrification Goals



– Results

- Lighting/lighting controls upgrade across 40 City facilities will result in approximately \$155,000 savings per year with a simple payback of 5.5 years
- Equipment at the End of Service Life
- Majority of Equipment
 - 15+ Years Old (63% of Total Equipment)
 - Operates with R-22 Refrigerant (66% of Equipment)



Packaged HVAC Units Age Summary				
Age Range (Years)			Count	%
0	to	5	6	5%
6	to	10	23	18%
11	to	15	19	15%
16	to	20	11	8%
21	to	25	12	9%
24	to	30	58	44%
31	+		2	2%
Total			131	100%

Operating Refrigerant		
Type	Count	%
410A	44	34%
R-22	84	66%
Total	128	100%

*Missing 3 Units are HV Units without Cooling Capabilities




– Scope Overview

- Total of 107 Sites
- Evaluated for Solar Application Based on:
 - Space Availability
 - Shading
 - Electrical Infrastructure
 - Ease of Construction



– Results

- Maximum Solar Potential of 7.2 MWdc at 17 Sites



– Results (Tier 1)

- Maximum Solar Potential of 3.2 MWdc at 11 Sites
- Tier 1 Recommendations
 - Adequate Space
 - No Shading or Obstructions
 - Optimal Orientation
 - Electrical Load to Offset
 - Point of Connection Identified

ECM Description	System Size (kWac)	System Size (kWdc)	Electrical Production (kWh)	ECM Implementation Cost (\$)
Finley Senior Center 76.5 kWdc Canopy	63	77	113,877	\$149,611
Fire Station 3 38.3 kWdc Roof Mount	33	38	55,992	\$86,251
Fire Station 4 38.3 kWdc Roof Mount	33	38	55,513	\$86,251
MSCN Garage Car Parking 657.9 kWdc Canopy	546	658	970,178	\$1,148,547
MSCN Garage Bus Parking 1017.5 kWdc Canopy	750	1,018	1,489,358	\$1,735,444
MSCS 183.6 kWdc Roof Mount	150	184	268,597	\$334,542
Sam Jones Hall 206.6 kWdc Rooftop & Canopy	200	207	303,554	\$377,807
Sonoma Brookwood Ctr 38.3 kWdc Roof Mount	33	38	55,936	\$86,251
Finley Park Community Center 504.9 kWdc Canopy	400	505	745,329	\$888,914
Bayer Park and Gardens 38.3 kWdc Canopy	33	38	56,792	\$86,251
Bayer Park and Gardens 15.3 kWdc Roof Mount	12	15	22,670	\$47,374
Gavlin Community Park 229.5 kWdc Canopy	192	230	342,317	\$411,724
Northwest Community Park 153 kWdc Canopy	133	153	597,492	\$285,005
TOTAL	2,578	3,198	5,077,605	\$5,723,972

– Results (Tier 2)



- Maximum Solar Potential of 4.0 MWdc at 6 Sites
- Tier 2 Recommendations
 - Adequate Space
 - No Shading or Obstructions
 - Optimal Orientation
 - Electrical Load to Offset
 - Point of Connection Identified

Tier 2 Solar PV Summary of Energy Production and Implementation Costs				
ECM Description	System Size (kWac)	System Size (kWdc)	Electrical Production (kWh)	ECM Implementation Cost (\$)
A Place to Play 2237 kWdc Ground Mount	1,750	2,237	3,486,103	\$3,775,908
A Place to Play 497.3 kWdc Canopy	375	497	732,489	\$859,247
Coffee Park 535.5 kWdc Canopy	438	536	797,139	\$829,393
Finali Park 76.5 kWdc Canopy	63	77	112,597	\$149,611
Southwest Community Park 198.9 kWdc Canopy	158	199	294,702	\$357,789
Hidden Valley Park 153 kWdc Canopy	125	153	227,754	\$279,222
Rincon Valley Community Park 306 kWdc Canopy	250	306	455,508	\$538,443
Total	3,158	4,004	6,106,292	\$6,789,613



– Scope Overview

- Investigate Microgrid Viability for Two Groups of Facilities



– Scope Overview

- Investigate Microgrid Viability for Two Groups of Facilities
- Group 1
 - 18 Buildings
 - 4 Unique Address

Microgrid Group 1			
A	B	C	D
Maintenance Service Center North 55 Stony Point Road	Fire Training Center 2126 West College Avenue	Finley Community Center 2060 West College Avenue	Maintenance Service Center South 69 Stony Circle
MSCN Admin/Lab building	Fire Training Tower	Finley Senior Wing	MSCS
MSCN Shop building	Fire Training storage building 1	Finley Community Center	
MSCN Warehouse	Fire Training office 1		
MSCN Garage	Fire Training classroom 2		
MSCN Vehicle Storage Building	Fire Training classroom 3		
MSCN Steam Cleaning Station	Fire Training storage building 2		
MSCN Wash Station #1			
Transit Operations Building			
Transit Wash Station Building			
9	6	2	1

– Scope Overview

- Investigate Microgrid Viability for Two Groups of Facilities
- Group 2
 - 7 Buildings
 - 4 Unique Address

Microgrid Group 2			
A	B	C	D
City Hall	Public Safety Building	City Hall Annex	Chamber Building
100 Santa Rosa Avenue	965 Sonoma Avenue	90 Santa Rosa Avenue	555 1st Street Santa Rosa
City Hall 2-5	PSB	City Hall Annex	Chamber Building-637 1st St
City Hall 6-8	PSB storage building		
City Hall 1, 9-11			
3	2	1	1

– Results

- Seven (7) Individual Microgrids

Microgrid Implementation Cost Summary					
Facility	Battery Energy Storage System	Solar PV (kWac)	Stand By Generator (kW)	Implementation Cost (\$)	O&M Costs (\$)
MSCN	840 kWh / 200 kW	400	365	\$1,991,000	\$35,000
MSCS	106 kWh / 46 kW	150	100	\$905,000	\$10,000
City Hall	210 kWh / 50 kW	0	450	\$923,500	\$25,000
City Hall Annex	210 kWh / 50 kW	0	450	\$923,500	\$25,000
PSB	840 kWh / 200 kW	0	365	\$1,635,000	\$25,000
Finley Park Senior Center	210 kWh / 50 kW	310	100	\$1,467,000	\$25,000
Finley Park Community Center	132 kWh / 58 kW	63	100	\$933,000	\$17,500
TOTAL		613	1,930	\$8,778,000	\$162,500

AECOM

Imagine it.
Delivered.