



City of Santa Rosa

Legislation Details

File #: 18-557BPU **Version:** 1 **Name:** Water Quality Lifting Advisory
Type: BPU- Report **Status:** Agenda Ready
File created: 9/12/2018 **In control:** Board of Public Utilities
On agenda: 9/20/2018 **Final action:**
Title: REPORT - PLAN FOR LIFTING THE ADVISORY IN THE FOUNTAINGROVE AREA

BACKGROUND: On November 10, 2017, Santa Rosa Water issued a Water Quality Advisory for an isolated area of Fountaingrove due to contamination that was caused by the October fires. In collaboration with State Water Board Division of Drinking Water (DDW) and US EPA regulators as well as water quality experts, Water Department staff has conducted a thorough investigation to confirm that the fire caused the contamination, to identify the sources of the contamination, and guided by the data, determined that targeted replacement of the system would likely restore water quality. The City has completed replacement of all water service lines and blow off valves, as well as targeted replacement of three mainlines in the Water Quality Advisory Area. Working in collaboration with DDW, the Water Department has developed a plan for lifting the water quality advisory in the Fountaingrove Area, which consists of sampling to confirm water quality has been restored as well as post advisory flushing and monitoring to ensure the contamination has been remediated and will not re-occur over time.

RECOMMENDATION: It is recommended by the Water Department that the Board, by motion, accept the report on the plan for lifting the advisory from the Water Quality Advisory area in a portion of Fountaingrove.

Sponsors: Board of Public Utilities

Indexes: Not a Project

Code sections:

Attachments: 1. Staff Report, 2. Attachment 1, 3. Presentation

Date	Ver.	Action By	Action	Result
9/20/2018	1	Board of Public Utilities	approved	Pass