



City of Santa Rosa

Legislation Details

File #: 21-312BPU **Version:** 1 **Name:** A Place to Play Emergency Well Pump Station
Type: BPU- Report **Status:** Agenda Ready
File created: 10/11/2021 **In control:** Board of Public Utilities
On agenda: 10/21/2021 **Final action:**
Title: REPORT - CONTRACT AWARD - REQUEST FOR CHANGE- OF- SCOPE CHANGE ORDER- EMERGENCY WELL PUMP STATION - A PLACE TO PLAY

BACKGROUND: During project construction, the results of routine well water quality sampling and analysis revealed arsenic levels that exceeded drinking water standards (also referred to as maximum contamination levels or MCLs). Based on these results, additional arsenic removal treatment is recommended as part of the project. This change order would provide additional funds and allow Team Ghilotti, Inc. (TGI) to implement design revisions necessary to reduce arsenic levels in groundwater to below MCLs.

RECOMMENDATION: It is recommended by the Water and Transportation and Public Works Departments that the Board of Public Utilities, by motion, approve a Change-of-Scope contract change order to include an arsenic removal treatment process for Construction Contract No. C01965 with Team Ghilotti, Inc., of Petaluma, California (TGI) by \$870,369.00, and authorize a total contract amount, including a 10% contingency, of \$3,035,618.94.

Sponsors: Board of Public Utilities

Indexes: Exempt Project

Code sections:

Attachments: 1. Staff Report, 2. Presentation (added 10/20/21)

Date	Ver.	Action By	Action	Result
10/21/2021	1	Board of Public Utilities	approved	Pass