



# City of Santa Rosa

## Legislation Details

<b>File #:</b>	23-314BPU	<b>Version:</b>	1	<b>Name:</b>	Adoption of MND and MMRP - Fulton Rd Sewer Main
<b>Type:</b>	BPU- Report	<b>Status:</b>			Agenda Ready
<b>File created:</b>	7/24/2023	<b>In control:</b>			Board of Public Utilities
<b>On agenda:</b>	8/3/2023	<b>Final action:</b>			
<b>Title:</b>	REPORT - ADOPTION OF A MITIGATED NEGATIVE DECLARATION AND MITIGATION MONITORING AND REPORTING PROGRAM AND PROJECT APPROVAL FOR THE FULTON RD SEWER MAIN IMPROVEMENTS, WEST 3RD ST TO SANTA ROSA CREEK				
	<p>BACKGROUND: Beginning in 2009, closed-circuit television (CCTV) inspection observed various abnormalities in a section of an existing sewer main located at the west side of Fulton Road, from West 3rd Street to just north of Santa Rosa Creek. Based on the best available information, it has been determined the slope of the existing sewer main is not consistent with City standards and the polyethylene (PE) liner is irregular and deforming into an upside-down 'U' shape, resulting in restriction of flow such that staff has concluded this section of sewer is compromised. This proposed resolution will adopt the Mitigated Negative Declaration (MND), adopt the Mitigation Monitoring and Reporting Program (MMRP), and approve the Fulton Rd Sewer Main Improvements, West 3rd St to Santa Rosa Creek Project (Project). The proposed resolution will also direct City staff to file a Notice of Determination for the Project pursuant to the California Environmental Quality Act (CEQA) Guidelines.</p> <p>RECOMMENDATION: It is recommended by the Transportation and Public Works Department and Santa Rosa Water that the Board of Public Utilities, by resolution: 1) adopt the Mitigated Negative Declaration for the Fulton Rd Sewer Main Improvements, West 3rd St to Santa Rosa Creek Project; 2) adopt the Mitigation Monitoring and Reporting Program; 3) approve the Fulton Rd Sewer Main Improvements, West 3rd St to Santa Rosa Creek Project; and 4) direct staff to file a Notice of Determination.</p>				
<b>Sponsors:</b>	Water, Board of Public Utilities				
<b>Indexes:</b>	Mitigated Negative Declaration				
<b>Code sections:</b>					
<b>Attachments:</b>	1. Staff Report, 2. Attachment 1 - Project Overview, 3. Attachment 2 - Initial Study Mitigated Negative Declaration MMRP, 4. Attachment 3 - Response to Comments, 5. Resolution, 6. Attachment to Resolution - Mitigation Monitoring And Reporting Plan, 7. Presentation, 8. BPU Resolution No. 1326				

Date	Ver.	Action By	Action	Result
8/3/2023	1	Board of Public Utilities	approved	Pass