



City of Santa Rosa

Legislation Details

File #: 23-081ZA **Version:** 1 **Name:** Above ground storage tank/canopy
Type: ZA- Agenda Item **Status:** In Committee
File created: 12/14/2023 **In control:** Zoning Administrator
On agenda: 12/21/2023 **Final action:**
Title: PUBLIC MEETING - NEW ABOVE GROUND STORAGE TANK AND CANOPY - DESIGN REVIEW - 3965 OCCIDENTAL RD - DR23-032

BACKGROUND: Minor Design Review to install a new 8,000-gallon, aboveground fuel storage tank, new fuel dispensing piping equipment and dispenser units, upgrade the electrical system, and install a new tank monitor unit. The proposed project proposes constructing a new 26' x 37' steel framed canopy over the fueling area. The canopy height is 19'-6" to the top of the canopy fascia. The project will remove and dispose of the existing 5,000-gallon underground fuel storage tank and remove and dispose of all associated fuel dispensing facilities, structures, piping, electrical conduits, equipment, fitting, and amenities. This project is exempt from the California Environmentally Quality Act (CEQA).

PROJECT PLANNER: Monet Sheikhal

Sponsors: Zoning Administrator

Indexes: Exempt Project

Code sections:

Attachments: 1. Attachment 1 - Site Plan, 2. Resolution, 3. Exhibit A, 4. Presentation

Date	Ver.	Action By	Action	Result
12/21/2023	1	Zoning Administrator		