

DEVELOPMENT ADVISORY COMMITTEE
(September 4, 2024)

ACACIA VILLAGE

Project Description

The Acacia Village project (Project) proposes to construct 25 single-family detached residential units, of which three will be designated for low-income owners. The project entitlements include a Density Bonus for five additional units; a Conditional Use Permit for a small lot subdivision; and Tentative Map to subdivide a 2.5-acre area into 25 individual residential lots and common area.

LOCATION 746 Acacia Lane

APN 182-520-050

GENERAL PLAN LAND USE Low Density Residential

ZONE CLASSIFICATION

 EXISTING R-1-6 (Single-family Residential)

 PROPOSED R-1-6 (Single-family Residential)

OWNER/APPLICANT Robert Upton, Acacia Village LLC

ADDRESS 12555 Dunbar Road
Glen Ellen, CA 95442

ENGINEER/SURVEYOR Firma Design Group

ADDRESS 418 B Street
Santa Rosa, CA 95401

REPRESENTATIVE Robert Upton

ADDRESS 12555 Dunbar Road
Glen Ellen, CA 95442

FILE NUMBER PRJ24-006

CASE PLANNER Suzanne Hartman

PROJECT ENGINEER Jesus McKeag

Background

On June 27, 2019, the Planning Commission approved the Acacia Village project.

On December 27, 2022, no further requests for a time extension were received and the project entitlements expired.

On April 15, 2024, new Project applications were submitted to the Planning and Economic Development Department to resurrect the previously approved Acacia Village Project.

Conditions of Approval

The following summary constitutes the recommended conditions of approval from City departments on the subject application/development based on plans stamped received April 15, 2024.

1. Developer's engineer shall obtain the current city Design and Construction Standards and the Community Development Department's Standard Conditions of Approval dated August 27, 2008, and comply with all requirements therein unless specifically waived or altered by written variance by the City Engineer.
2. Developer's engineer shall comply with all requirements of the City Storm Water Low Impact Development Technical Design Manual in effect at the time this application was deemed complete.
3. At the time of the City of Santa Rosa's (City) previous acceptance of this Project's proposed onsite offset, the North Coast Regional Water Quality Control Board's (Regional Board) direction was that the local co-permittees could independently approve onsite offsets for both the water quality treatment and volume capture/hydromodification. The Regional Board has since changed their direction on this. Co-permittees can now only approve onsite offsets for volume capture/hydromodification. Proposals of onsite offset for landscaped water quality treatment will require Regional Board approval brought to the Regional Board by the respective co-permittee. The City received permission that projects that received previous acceptance of onsite offsets by staff can still be honored and allowed to proceed without the Regional Board's approval. While this project does not yet have approved improvement plans signed by the City, as long as there is no substantial change in approach (e.g. change in LID type/priority, change in location of the onsite offset features, switch to offsite offset, etc.) to this Project's onsite offset design, the Project's onsite offset does not need Regional Board approval. The proposed design will still have to meet all other regional LID design requirements and comments by the City to receive approved improvement plans from the City. All projects that propose an onsite offset for landscaped water quality treatment will need to be brought to the Regional Board by a co-permittee for Regional Board approval if they have not received acceptance (or conditional acceptance) of the onsite offset design approach by the City prior to April 2024

4. Submit landscape and irrigation plans in conformance with the Water Efficient Landscape Ordinance adopted by the Santa Rosa City Council, Ordinance 4051, on December 1, 2015.

Planning Conditions

5. Fourteen (14) days prior to the removal of any trees or structures, or commencement of construction activities, the developer shall consult with a qualified bat biologist, who is defined as a bat biologist and holds a California Department of Fish and Wildlife (CDFW) collection permit and a Memorandum of Understanding with CDFW allow the biologist to handle and collect bats. The bat biologist shall identify and supervise any necessary protective measures to avoid impacts to known bat habitat in preparation for construction activities.
6. If construction activities, including tree pruning, tree removal, ground disturbing activities, or construction activities commence between February 1 and August 31, a pre-construction survey of the open grassland areas and trees for nesting birds (migratory song birds and raptors) shall be performed not more than seven (7) days prior to the start of these activities. The pre-construction survey shall be conducted by a qualified avian biologist.
7. Compliance with City Graffiti Abatement Program Standards for Graffiti Removal (City Code 10-17.080).
8. A qualified archaeologist or tribal monitor shall be on-site to monitor initial ground disturbing activities.
9. Conditions, Covenants, and Restrictions (CC&R's) in a form approved by the Neighborhood Revitalization Program, shall be recorded on each lot. The CC&R's are intended to create a framework by which investor owned properties and common areas are managed and maintained. At a minimum, the CC&R's shall contain provision for:
 - a. Residential occupancy standards;
 - b. Maintenance and habitability requirements;
 - c. Prohibit the use of garages for the storage of personal property if it precludes a vehicle also being parked within the structure;
 - d. Prohibition of nuisances and offensive activities including: graffiti, illegal drugs, violent acts and criminal gang behavior;
 - e. Resident and guest parking system;

- f. The Homeowners Association (HOA) shall be responsible for regular maintenance of the gang mailbox area(s). The gang mailbox area(s) shall be kept litter free and maintained in good condition;
 - g. The developer shall negotiate a garbage pick-up time later than 8:00 a.m.
 - h. The HOA will provide regular maintenance for all common areas including landscaping, garbage enclosures, pavilion/gathering area and parking lots around structures;
 - i. The HOA shall provide regular maintenance for all street trees.
- 10. Trash enclosures shall be fully enclosed structures concealing garbage receptacles from public view and will provide a man-door to allow single person access to deposit waste.
 - 11. The project shall comply with the Noise Ordinance, City Code Chapter 17-16.
 - 12. The project shall comply with the Tree Ordinance, City Code Chapter 17-24.
 - 13. The project shall comply with outdoor lighting standards set forth in Zoning Code Section 20-30.080.

MAPPING AND PRIVATE EASEMENT DEDICATION

- 14. All final and parcel maps shall comply with all currently adopted ordinances, resolutions, and policies of the City of Santa Rosa and the State Subdivision Map Act.
- 15. All costs associated with map, plan, easement, plat, legal description, and/or support document preparation shall be the sole responsibility of the subdivider.
- 16. A Final Map as defined by the applicable provisions of the State of California Subdivision Map Act shall be required for this 25-unit subdivision.
- 17. The formation of a Homeowners Association, responsible for ownership and maintenance of the common area and common site improvements, is required for this subdivision. Two copies of the documents creating the Association and the Covenants, Conditions and Restrictions governing the Association shall be submitted to the Department of Planning & Economic Development – Engineering for review.
- 18. The Developer shall provide a means acceptable to the City to fund the maintenance of the Parcels A through C into perpetuity through a special tax district, CC&R's, property owners association(s), and/or other acceptable

method. No Parcel nor private improvement shall be dedicated to the City of Santa Rosa in fee title on the face of the map.

In the event the developer chooses a method of assuring perpetual maintenance which is subject to revocation by the property owners by an election or other means of termination, Developers shall establish a backup alternative which will be capable of automatically assuming the maintenance funding obligation in the event the primary method is no longer available.

The documents creating the method for permanent maintenance and any necessary backup alternative(s) shall be subject to and have been approved by the City Attorney and the City Engineer and in place prior to approval of the final map. The plans and standards for maintenance shall be subject to approval by the Planning & Economic Development.

19. The Final or Parcel Map shall be annotated on the information sheet as follows:
“Water and sewer demand fees and processing fees are based on the number and type of units to be built on each lot. Water and sewer demand, processing and meter installation fees must be paid prior to the issuance of a Building Permit for the respective lot.”
20. If during plan check the Fire Department determines that a public emergency vehicle access easement (EVA) is required, it shall be dedicated to the City of Santa Rosa on the face of the map.
21. The final map shall show;
 - a. A private drainage easement over the entire area of Parcels A through C in favor of all the lots created by this subdivision
 - b. A joint private drainage easement over lots 15 through 17
 - c. A parking easement over Parcels A and C in favor of lots 1 through 19
 - d. Any reciprocal ingress / egress easements deemed needed during plan check.

PARCEL AND EASEMENT DEDICATIONS

22. Vehicular access rights shall be dedicated to the City along the Acacia Lane frontage of the site except at the planned street entrances to the project and any emergency access points that may be required but do not appear on the present plan.
23. This is a 25 Lot Subdivision creating 25 residential units with private use areas on Parcels A through C. The formation of a Homeowners Association, responsible for ownership and maintenance of the common area building and site improvements is required for this subdivision. The documents creating the Association and the Covenants, Conditions and Restrictions (CC&Rs) governing the Association shall be required to be submitted with the First plan check for

review by the City Attorney. The approved CC&Rs shall be recorded contemporaneously with the Final Map.

24. A public utility easement shall be dedicated over portions of Parcels A through C to the satisfaction to the City Engineer during plan check of the public improvement plans.

PUBLIC STREET IMPROVEMENTS

25. All public and private improvements, both on-site and off-site; all rights-of-way and easement acquisitions, be they on-site or off-site; and all removal, relocation, or undergrounding of existing public utilities and any coordination thereof required or necessitated as a result of the review and approval of the project and the cost thereof shall be the obligation of the subdivider unless express written provision to the contrary is agreed to by the City. The full installation of all such required improvements to the satisfaction of the City Engineer shall be completed prior to the acceptance of the improvements by the City.
26. Civil improvement plans shall be prepared by a Registered Civil Engineer licensed to practice in the State of California for approval by the City Engineer.
27. **Acacia** Lane shall be dedicated and improved as a Minor Street along the entire project frontage. Half width street improvements for the project side of the street shall consist of dedicating sufficient right of way in fee and widening the roadway section such that the resulting curb to curb width of roadway is 36-feet including the gutter pan. See Prospect Village Unit 2, Phase 1 Final Map (City File 2018-0022) and Improvement Plans (City File 2013-0040) for the location of the curb on the opposite side of Acacia. A 5-foot contiguous sidewalk shall be installed back of curb. See the City Standards 200 E and 230 B for dimensions and widths of easement dedication.
28. Improvements to **Acacia** Ln shall include a 24-foot minimum width City Standard 250 A, C or D drive approach for Parcel A
29. **Winding Creek** Avenue shall be dedicated and improved as a Minor Street along the entire project frontage.
 - a. Half width street improvements for the project side of the street shall consist of a 12-foot travel lane with planter strip behind a sidewalk with a standard curb and gutter. See the City Standards 200 E and 230 B for dimensions and widths of easement dedication.
 - b. The curb line at the northwesterly terminus of the project improvements shall transition to the existing alignment with a Standard 212 15:1 taper, Standard 213 reversing curves or as approved by the City Engineer during plan check.
 - c. The sidewalk at the northwesterly terminus of the project improvements shall transition to the existing alignment through Standard 231 reversing curves.

- d. Half width street improvements for the opposite side of the street shall consist of a 12-foot travel lane with an AC Berm and no asphalt path. See the City Standards 200 K for dimensions.
 - e. Sidewalk barricades per City Standard 236 shall be installed at the end of the sidewalk.
30. Improvements to Winding Creek Ave shall include;
- a. 12-foot minimum width City Standard 250 B drive approaches for lots 22 through 25 or as approved by the City Engineer through a Variance during plan check
 - b. a 24-foot minimum width City Standard 250 A, C or D drive approach for Parcel C
31. The curb return radii shall be 25-feet for both returns on the easterly side of Acacia. Right-of-way for the curb return between improved frontages shall be dedicated so that a City Standard 232A handicap ramp and the 4-foot sidewalk landing are contained within 6 inches of the right-of-way at curb returns. The curb return on the non-project side of Winding Creek shall be AC Berm per Standard 200 K and taper to existing conditions at the subdivision boundary.
32. The minimum and maximum cross-slope for all streets shall be 2% and 5% respectively. Minimum gutter slope for all streets shall be 0.5%.
33. Existing streets being cut by new services will require edge grinding per City Standard 209, trenching per Standard 215, and an A.C. overlay.
34. Installation of street lights and the street lighting pattern will be determined during plan check phase of the improvement plans as approved by the City Engineer.
- a. Decorative luminaire Street lighting shall be installed per City Standard 615D for Street Lights.
 - b. City Standard 611 cobra style street lights are to be installed along the frontage to current spacing requirements, using LEOTEK LED fixtures. Street light spacing, wattages, and locations will be determined during the improvement plan review process.
35. Electrical boxes for new and/or relocated street lights and signals shall be provided with grounded vandal resistant inserts, McCain Tamper Resistant Inserts or City approved equal, in street light pull boxes at locations as directed by the City. Catalog cuts shall be provided with the first plan check submittal for review and approval by the City Engineer. The street light improvement plans shall include the following note; "The contractor may use their own locks during construction for ease of access, however once the conductors in the pull box are live the contractor shall coordinate with the City Inspector to have the City lock installed. Electrical pull boxes in planter strips shall be provided with a 2-foot concrete apron around box."
36. With the exception of existing overhead electrical main feeder lines, all existing wire-distributed utility facilities which are on the proposed or existing rights-of-way, roadways, walkways, easements, etc. within the subject subdivision or along

roadways required to be improved in conjunction with the subject subdivision may be required to be removed and undergrounded prior to the construction of proposed improvements and all poles along the frontage(s) shall be removed. All existing overhead service drops which emanate from the existing poles and overhead facilities required to be removed and undergrounded, and which serve existing structures on both sides of the street within the boundaries of the road improvements of the subject subdivision shall be undergrounded to the main service switch or service entrance to such structures. Where existing overhead electrical main feeder lines are left overhead, conduit shall be placed in the ground to provide for future undergrounding of the lines.

37. New services (electrical, telephone, cable or conduit) to new structures shall be underground.
38. Developer shall coordinate, and where necessary, pay for the relocation of any power poles or other existing public utilities, as necessary.
39. Two copies of the Phase 1 Environmental Site Assessment shall be included with the submittal of the first plan check. 1 copy is to be submitted directly to the Fire Department and review fee paid, a copy of the receipt shall be submitted with the remaining copy to the Engineering Department. Grading, demolition or construction permits shall not be issued until the Fire Department has reviewed and cleared the Phase 1 Study.

TRAFFIC

40. The height of signs, vegetation or other obstructions near street intersections shall maintain clear line of sight for all vehicles approaching the intersection to the satisfaction of the City Traffic Engineer during review of (Building Permit, Encroachment Permit, Improvement Plans).
41. Vegetation over 3-feet in height shall be planted no closer than 40-feet from stop bar of stop sign controlled intersections.

PRIVATE PARKING PARCEL AND DRIVEWAY IMPROVEMENTS

42. The common parking parcels shall be covered by joint access and utility easements. (Note: the California Department of Real Estate may require the formation of a homeowners association for maintenance of common facilities.) The parking lot shall be built to Standard 270 and bordered with concrete curb and gutter.
43. Clear backup of 46-feet from garage face to opposing face of curb shall be provided on all driveways.
44. Parking spaces in front of garage faces in common driveways shall be a minimum of 19-feet by 9-feet and perpendicular to the garage face. If no parking is allowed in front of garage faces the driveway approach shall be 5-feet or less.

45. Drive aisles through common driveways shall be a minimum width of 12-feet for one-way traffic and 24-feet for two-way traffic. If parking is proposed along the driveway these minimums may be increased. The full length of common driveways shall be paved.
46. Private street lights shall be installed on all private streets and shall meet City Standards for minimum average maintained foot-candle and the uniformity ratio for a minor street. All private lighting shall be owned and maintained by the homeowners' association. Private lighting fixtures shall be subject to staff review.

STORM DRAINAGE

47. Drainage facilities and drainage easements shall be provided to the satisfaction of the City Engineer or the Chief Engineer of the Sonoma County Water Agency at the subdivider's expense.
48. Drainage facilities shall be designed per the Flood Control Design Criteria manual of the Sonoma County Water Agency. If flows exceed street capacity, flows shall be conducted via an underground drainage system (with minimum 15" diameter and maximum 72" diameter pipe sizes) to the nearest approved downstream facility possessing adequate capacity to accept the runoff, per the City's design requirements. Such runoff systems shall be placed within public street right-of-way wherever possible.
49. Any off-site storm water runoff shall be conveyed across the project site in a separate bypass storm drain system, or shall be fully treated. Collection points along the boundary of the project shall convey storm water to the bypass system to separate treated and untreated storm water. All storm water systems shall be sized to convey the storm water per Sonoma County Water Agency standards.
50. Lots shall be drained in a manner so as not to adversely affect the adjacent lot. No lot-to-lot overland drainage is permitted except that lots may drain overland to parking parcels. Cross-lot drainage shall be piped through a private storm drain easement. Lot drainage and private storm drain facilities shall be approved by the Chief Building Official or designated representative. Private drainage inlets and lines shall be required and shall be privately owned and maintained.
51. All drainage flows from offsite shall be intercepted at the property line and conveyed through a private system to discharge into the public right of way.
52. Concentrated drainage flows shall not be permitted to cross sidewalks, or slope areas subject to erosion problems.
53. An adequate drainage system shall be required to drain rear yards and patio areas. Private underground storm drain systems and drainage easements are required for any lot-to-lot drainage.

STORM WATER COMPLIANCE (SWLID)

54. The developer's engineer shall comply with all requirements of the latest edition of the City Standard Urban Storm Water Mitigation Plan Guidelines. Final Public Improvement Plans shall incorporate all SWLID Best Management Practices (BMPs) and shall be accompanied by a Final Storm Water Mitigation Plan which shall address the storm water quality and quantity. Final Public Improvement Plans shall be accompanied by a maintenance agreement or comparable document to assure continuous maintenance in perpetuity of the SWLID BMPs and shall include a maintenance schedule.
55. Perpetual maintenance of SWLID BMPs shall be the responsibility of one or more of the following as approved by the City of Santa Rosa:
 - a. The individual homeowners fronting or owning these BMPs. Individual owners shall be responsible for performing and documenting an annual inspection of the BMPs on their respective properties. The annual reports shall be retained by the private property owner for a period of the latest five years, and shall be made available to the City upon request.
 - b. A Homeowner's Association or Property Owners Association. If perpetual maintenance of these BMPs is through a Homeowner's Association or Property Owner's Association, the documents creating the Association and the Covenants, Conditions and Restrictions governing the Association shall be submitted to the City Attorney's Office and the Department of Community Development for review.
 - c. A special tax district for public BMP facilities.
 - d. An alternate means acceptable to the City of Santa Rosa

After the SWLID BMP improvements have been constructed, the developers Civil Engineer is to prepare and sign a written certification that they were constructed and installed as required or per the manufacturer's recommendation. Written certification of SWLID BMPs is to be received by the City prior to acceptance of subdivision improvements.

56. A Final Storm Water Mitigation Plan (SWMP) using Best Management Practices (BMP) is to be included with the Improvement Plans and Final Map submitted for the First Plan Check. Private improvements required by the Final SWMP are to be contained on the individual properties and are maintained by the property owners. All SWMP details and improvements are to be included in the Subdivision Improvement Plans. The maintenance schedule and the Final SWLID are to be included as part of the CC&Rs recorded with the Final Map. The information sheet of the Final Map shall note the maintenance schedule required by the Final SWLID is to be followed by the property owner and all logs are to be made available for review by the City on an annual basis.

57. Use of vortex separators for water treatment is not allowed in Santa Rosa. In-line filters used for water treatment are limited to those tested by independent testing laboratories and approved by the California Regional Water Quality Control Board. The filter separator currently approved for use in Sonoma County is limited to the Hydro International, www.hydro-international.biz, "Up-Flo Filter". Filter systems other than the approved "Up-Flo Filter" will require full testing data from an independent testing laboratory be submitted for review and approval by the California Regional Water Control Board prior to approval of subdivision improvement plans.
58. All SWLID LID BMPs contained on Parcels A through C common area shall be owned and maintained by the HOA and is subject to covenants, conditions, and restrictions which will be recorded contemporaneously with the filing of this map.
59. If a public Drainage Easement over any Parcel is determined during plan check to be needed, it shall be offered to and will be accepted by the City of Santa Rosa.

GRADING

60. Obtain a demolition permit for the structures to be removed.
61. Provide a geotechnical investigation and soils report with the building permit application. The investigation shall include subsurface exploration and the report shall include grading, drainage, paving and foundation design recommendations.
62. Obtain a building permit for the proposed project.

WATER AND WASTEWATER

63. Water and sewer systems and appurtenances thereto shall be designed to serve the project in accordance with the City of Santa Rosa Design and Construction Standards and shall be constructed to the satisfaction of the City Engineer.
64. All underground improvements including sewer lines, water lines, storm drains, public utility facilities, and house services shall be installed, tested, and approved prior to the paving of any project streets.
65. This project is subject to the latest fees in effect at the time of connection or Building Permit issuance.
66. Fees for inspection of publicly maintained water and/or sewer facilities constructed with this project must be paid prior to scheduling of work as prescribed in City Specifications.

67. Install mains with constant alignment wherever possible, minimum 3-feet from the lip of gutter 4-feet from centerline monuments.
68. Private sewer mains shall be a minimum of 6" in diameter and public mains shall be a minimum of 8" in diameter. Connections between private and public sewer mains shall be at manholes. Public water mains must be sized to meet criteria per Section VII of the Water System Design Standards.
69. For purposes of leak detection and maintenance access, no reinforced concrete may be designed over publicly maintained water or sewer facilities. Un-reinforced concrete will be allowed under special circumstances such as crosswalks. Water system valves must be located outside of the concrete area.
70. Onsite private water and sewer systems and appurtenances thereto shall meet all applicable City, State and Federal laws, codes and guidelines to the satisfaction of the Chief Building Official.
71. On-site private water mains shall be installed as part of this project.
72. Install a 8-inch public sewer main in Winding Creek Ave along the frontage of Lot 25 and connecting to a manhole at the intersection of Winding Creek Ave with Acacia Ln.
73. Separate sewer laterals shall be installed for Lots 20 to 25.
74. Any existing sewer lateral that will not be used must be abandoned at the main per City Sewer System Design Standards Section XII, Abandonment of Sewer Mains and Services and City Standard 507 under an encroachment permit.
75. Public water mains must be sized to meet criteria per Section VII of the Water System Design Standards. Water mains shall be located parallel to street centerlines unless conflicts with other underground utilities cannot be avoided.
76. Public water mains shall be sized to meet minimum Fire Code requirements in addition to domestic and irrigation demands. The minimum new public main size shall be 8 inches. Alignment shall be in accordance with the provisions of Standard 871 or as directed by the Engineer. An easement shall be provided over any public water system when it is installed outside a public right-of-way.
77. Conform to the latest revision of the State of California State Water Resources Control Board (SWRCB) "Criteria for the Separation of Water Mains and Non-Potable Pipelines" (See Appendix "A" of the Santa Rosa Water Distribution Standard Specifications) and any modifications herein or as approved by both the SWRCB Division of Drinking Water and the Water Department Director. 4-inch and larger service laterals shall the same separation requirements as water mains.

78. The minimum horizontal separation from storm drains, monuments, gas, electrical, and telephone lines shall be 4 feet clear between facilities, or from a metallic pipeline with an induced current or from an anode field shall be 5 feet, except at crossings.
79. All public water mains shall be designed a minimum of 5 feet from all structures, such as manholes or drop inlets. Provide a minimum of 3 feet separation from the lip of gutter to edge of pipe for future maintenance. The edge of water main pipes shall be designed a minimum of 5 feet from the edge of easements.
80. The applicant shall extend an 8-inch public water main from the east end of the existing main in Winding Creek, connecting to the existing main in Acacia Ln per City Standards.
81. Connection to the existing main will require a shut down for a tie-in inspection. Call Water Engineering Services for fees and scheduling. Advance notice is required.
82. Water services and meters must be provided per Section X of the Water System Design Standards and shall be sized to meet domestic, irrigation, and fire protection uses. Any services placed in driveway areas shall have meters with traffic rated boxes.
83. Backflow prevention devices shall be designed and installed in accordance with current City Standards, State Health Code Title 17, and as required by the Director of Santa Rosa Water.
84. Reduced Pressure back flow per City Standard 876 will be required on all irrigation services.
85. Double check back flow per City Standard 875 will be required on all water services. The flow calculations shall be submitted to the Santa Rosa Water Department during the plan check phase of the Improvement Plans or Encroachment Permit to determine adequate sizing.
86. Design of hydrant locations shall be per City Standard 857, meet the Fire Code requirements and must be approved by the Fire Department for logistics and by Santa Rosa Water Department for maintainability.
87. Any existing water service that will not be used must be abandoned at the main per City Water System Design Standards Section XVIII, Abandonment of Water Mains and Services and City Standard 507 under an encroachment permit. The existing meter must be collected by the City Meter Shop. Call Water Engineering Services at 543-3950 to arrange pick up.
88. If a well exists on the property, one of the following conditions apply:

- a. Retention of wells must comply with City and County codes. An approved backflow prevention device must be installed on any connection to the City water system.
 - b. Abandonment of wells requires a permit from the Sonoma County Permit and Resource Management Department.
 - c. Wells may not serve more than one parcel, and any lines from existing wells that cross lot lines must be severed.
89. Wells may not serve more than one parcel, and any lines from existing wells that cross lot lines must be severed.
90. Any existing septic systems shall be removed under supervision of project Soils Engineer. Obtain Permits from the Sonoma County Permit and Resources Management Department. Obtain a City Building permit if an existing structure is being converted from a connection to the septic system to the public sewer system.
91. Where bio swales are required, meter boxes, cleanouts, fire hydrants, etc. must be located without conflict with the swales. Locations of infrastructure will be reviewed during plan check. No bio swales or SWLID BMP LID improvements shall cross public sewer, water, or storm drain utilities.
92. Provide a separate irrigation service. See Section X. O. of the Water System Design Standards.

Fire Conditions

93. Private onsite improvements related to the underground fire main; fire hydrants and fire sprinkler lines will be a deferred submittal to the Fire Department for application, review, and permit issuance.

Recreation and Parks Conditions

94. Street trees will be required and planted by the developer. Selection will be made from the City's approved master plan list and approved by the City's Parks Division. Planting shall be done in accordance with the City "Standards and Specifications for Planting Parkway Trees." Tree planting locations shall be marked by the City Parks Division Tree Section personnel. Contact Parks Division Tree Section 543-3422. Copies of the master street tree list and the standards are available at the Parks Division Office, 543-3770.

The Development Advisory Committee is an administrative committee designed to inform the Planning Commission of technical aspects of various matters which the Commission is to consider. The report of the Committee in no way constitutes approval or denial of the item under decision. Final approval or denial rests with the Planning Commission and/or

City Council and may or may not be subject to terms of this report.

Recommendation

 X Approval with conditions as set forth in this report

 Continuance

 Denial – Reasons:

 Final action referred to the Planning Commission

JESSICA JONES
Deputy Director - Planning
Planning and Economic Development