



**PROPOSED AST ELEVATION - SIDE**

SCALE: 1/4" = 1'-0"



**PROPOSED AST ELEVATION - END**

SCALE: 1/4" = 1'-0"



**PROPOSED AST PLAN**

SCALE: 1/4" = 1'-0"

NO.	DATE	REVISIONS DESCRIPTION

701 N. Parkcenter Dr.  
 Santa Ana, CA 92705  
 P: 714/500/8222 F: 714/978/2615  
 www.tait.com

San Diego  
 Phoenix  
 Denver  
 Sacramento



**PROJECT TITLE** PROPOSED AST PLAN AND CANOPY ELEVATIONS

**PROJECT ADDRESS**  
 PG&E CORPORATION YARD  
 3965 OCCIDENTAL ROAD  
 SANTA ROSA, CA 95401

**CLIENT**  
 PACIFIC GAS & ELECTRIC COMPANY  
 ENVIRONMENTAL MANAGEMENT  
 3965 OCCIDENTAL ROAD  
 SANTA ROSA, CA 95401

**CHECKED** S. IVERSON

**DRAWN BY** O. ORTIZ

**JOB NUMBER** PW9170

**DATE** 7/20/23

**SHEET** - OF -  
 A-1

**SCALE** NOTED



Since 1924

**P.D. McLAREN LIMITED**

**P.D.McLAREN LTD IS PROUD TO PRESENT  
THE FASTEST AND MOST RELIABLE  
COMMERCIAL UNIT ON THE MARKET**

**THE RDR HS**

**HIGH SPEED UNITS**





Since 1924

**P.D. McLAREN LIMITED**

***Model available :***

***HSx:*** Single product, single hose

***HSx-D1:*** Single product, dual hose

***HS2-D2:*** Dual product, dual hose (Dispenser only)

***HSx-SAT:*** Master unit and satellites

***HSx-X2:*** Single product, dual hose, one at the time

***Standard equipment:***

- Electronic Register with Heater
- Backlite Display
- Pulse Output Interface
- Stainless Steel Top and Sides
- 1-1/2 HP Motor/Pump (45to 225 LPM)
- Drip Collector Nozzle Boot
- Painted Upper & Lower Door Panels
- Solenoid Valve  
(in dispenser and dual hose units)
- 1-1/2" Meter
- Display Battery Backup
- Automatic Temperature Compensation
- Communication Options Interface
- Available with stainless-steel doors
- Weight & measures Canada Approved



**P.D. McLaren Limited**  
5069 Beresford Street  
Burnaby, British Columbia  
V5J 1H8 Canada  
**Phone: 604-437-0616**  
**Fax: 604-434-9120**

**P.D. McLaren Limited**  
6333, 35th Street S.E.  
Calgary, Alberta  
T2G 1N1 Canada  
**Phone: 403-287-1633**  
**Fax: 403-287-1663**

**P.D. McLaren Limited**  
Unit 27 - 520 Westney Road S.  
Ajax, Ontario  
L1S 6W6 Canada  
**Phone: 905-428-8403**  
**Fax: 905-428-8669**

PG&E Corporation Yard Fuel System Replacement  
Photo Exhibit



PHOTO 1: View east of existing fueling island and vehicle service building.



PHOTO 2: View south of existing fueling island.

PG&E Corporation Yard Fuel System Replacement  
Photo Exhibit



PHOTO 3: View west of existing fueling island.



PHOTO 4: View north of existing vehicle wash bay to remain.